SIEMENS

Product data sheet 3LD2203-1TL53



EMERG. STOP SWITCH 4-POLE IU=32, P/AC-23A AT 400V=11.5KW FRONT MOUNTING FOUR-HOLE MOUNTING ROTARY ACTUATOR RED/YELLOW (EMERG. STOP)

Similar to image

General technical details:				
product brand name		SENTRON		
product designation		main and EMERGENCY-OFF switches		
Type from device		fixed mounting		
Design of the operating mechanism		rotary actuator, red/yellow		
Protection class IP		IP65		
Number of poles		4		
Acceptability for application				
switch disconnector		Yes		
main switch		Yes		
safety cut-out switch		Yes		
emergency stop switch		Yes		
maintenance/repair switch		Yes		
Product equipment / interlock		Yes		
Type of the driving mechanism / motor drive		No		
Product extension / optional				
• motor drive		No		
• voltage trigger		No		
Ambient temperature / during operating	°C	-25 +55		

Insulation voltage / rated value V 690 Impulse voltage resistance / rated value V 6,000 Active power loss / per conductor / typical Mechanical operating cycles as operating time / of the main contacts / typical Protection against electrical shock Item designation / according to DIN EN 61346-2 S Item designation / according to DIN 40719 extendable after IEC 204-2 / according to IEC 750 Main circuit:	
Active power loss / per conductor / typical Mechanical operating cycles as operating time / of the main contacts / typical Protection against electrical shock Item designation / according to DIN EN 61346-2 S Item designation / according to DIN 40719 extendable after IEC 204-2 / according to IEC 750	
Mechanical operating cycles as operating time / of the main contacts / typical Protection against electrical shock finger-safe Item designation / according to DIN EN 61346-2 Item designation / according to DIN 40719 extendable after IEC S 204-2 / according to IEC 750	
Contacts / typical Protection against electrical shock finger-safe Item designation / according to DIN EN 61346-2 Item designation / according to DIN 40719 extendable after IEC S 204-2 / according to IEC 750	
Item designation / according to DIN EN 61346-2 Item designation / according to DIN 40719 extendable after IEC S 204-2 / according to IEC 750	
Item designation / according to DIN 40719 extendable after IEC S 204-2 / according to IEC 750	
204-2 / according to IEC 750	
Main circuit:	
Continuous current / rated value A 32	
Operating current / at AC-21 / rated value A 32	
Short-time current resistance (Icw) / at 690 V / limited to 1 s / A 640 rated value	
Operating frequency Hz 50 60	
Operating voltage / at 50/60 Hz / for AC / rated value V 690	
Service power / at AC-3	
• at 400 V / rated value kW 9.5	
• at 690 V / rated value kW 9.5	
Service power / at AC-23 A	
• at 400 V / rated value kW 11.5	
• at 690 V / rated value kW 11.5	
Operating cycles / maximum 1/h 50	
Auxiliary circuit:	
Number of NC contacts / for auxiliary contacts 0	
Number of NO contacts / for auxiliary contacts 0	
Number of change-over switches / for auxiliary contacts 0	
Continuous current / of the auxiliary contact / rated value A 10	
Operating voltage / of the auxiliary contacts / for AC / maximum V 500	
Insulation voltage / of the auxiliary switch / rated value V 500	
Short-circuit:	
Design of the fuse link / for short-circuit protection of the main circuit / necessary fuse gL/gG: 40 A	
Design of the fuse link / for short-circuit protection of the auxiliary switch / required fuse gL/gG: 10 A	
Installation/mounting/dimensions:	
Type of mounting front mounting	
• front mounting Yes	
• front mounting with central fixation No	

	Yes
	Yes
	No
mm	67
mm	83
mm	92.5
	mm

Connection type:	
Design of the electrical connection / for main current circuit	connection terminals
Design of the electrical connection / for auxiliary contact	connection terminals
Type of the connectable conductor cross-section / for main contacts	
• solid	1.5 16 mm2
finely stranded / with conductor end processing	10 mm²
• stranded	1.5 16 mm2
Type of connectable conductor cross section / for auxiliary contacts	
• solid	2x (0.75 to 2.5 mm2), 1x 4 mm2
• stranded	2x (0.75 2.5 mm2), 1x 4 mm2

Certificates/approvals:		
Verification of suitability		CSA / UL / CCC / GL / LRS / DNV / PRS
Conductor cross section that can be connected / for main contacts / solid / minimum	mm²	1.5
Conductor cross section that can be connected / for main contacts / solid / maximum	mm²	16
Conductor cross section that can be connected / for main contacts / stranded / minimum	mm²	1.5
Conductor cross section that can be connected / for main contacts / stranded / maximum	mm²	16
Conductor cross-section that can be connected / for main contacts / stranded wire / with conductor end processing / maximum	mm²	10
Conductor cross section that can be connected / for auxiliary contacts / solid / minimum	mm²	0.75
Conductor cross section that can be connected / for auxiliary contacts / solid / maximum	mm²	4
Conductor cross-section that can be connected / for auxiliary contact / stranded wire / with conductor end processing / minimum	mm²	0.75
Conductor cross-section that can be connected / for auxiliary contact / stranded wire / with conductor end processing / maximum	mm²	2.5
Conductor cross section that can be connected / for auxiliary contacts / stranded / min.	mm²	0.75

Conductor cross section that can be connected / for auxiliary contacts / stranded / max.

 $\,\mathrm{mm^2}$

4

Certificates/approvals:

General Product Approval





Test Certificates

Special Test Certificate

Shipping Approval





GL





other

Declaration of Conformity



Further information:

Information- and Downloadcenter (Catalogs, Brochures,...)

http://www.siemens.com/lowvoltage/catalogs

Industry Mall (Online ordering system)

http://www.siemens.com/lowvoltage/mall

Service&Support (Manuals, Certificates, Characteristics, FAQs,...)


http://support.automation.siemens.com/WW/view/en/3LD2203-1TL53/all


Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, ...)


http://www.automation.siemens.com/bilddb/cax_en.aspx?mlfb=3LD2203-1TL53


CAx-Online-Generator

http://www.siemens.com/cax









Bohrbild

last change:

Apr 9, 2012