SIEMENS

Product data sheet

3RT1054-1AP36



CONTACTOR,

55KW/400V/AC-3 AC(40...60HZ)/DC OPERATION UC 220...240V AUXIL. CONTACTS 2NO+2NC 3-POLE, SIZE S6 WITH BOX TERMINALS CONVENTIONAL **OPERATING MECHAN. SCREW TERMINAL**

General	detail	6.

General details:		
Product brand name		SIRIUS
product designation		power contactor
Size of the contactor		S6
Protection class IP / on the front		IP00
Degree of pollution		3
Installation altitude / at a height over sea level / maximum	m	2,000
Ambient temperature / during operating	°C	-25 +60
Active power loss / per conductor / typical	W	7
Item designation		
according to DIN EN 61346-2		Q
 according to DIN 40719 extendable after IEC 204-2 / according to IEC 750 		К
Mechanical operating cycles as operating time		
• of the contactor / typical		10,000,000
 of the contactor with added auxiliary switch block / typical 		10,000,000
 of the contactor with added electronics-compatible auxiliary switch block / typical 		5,000,000
Main circuit:		
Number of poles / for main current circuit		3

Number of NC contacts / for main contacts		0
Number of NO contacts / for main contacts		3
Operating current / at AC-1 / at 400 V / at 40 °C ambient temperature / rated value	A	160
Operating current / at AC-1 / at 400 V / at 60 °C ambient temperature / rated value	A	140
Operating current		
• at AC-3 / at 400 V / rated value	А	115
with 1 current path		
• at DC-1		
• at 24 V / rated value	А	160
• at 110 V / rated value	А	18
• at DC-3 / at DC-5		
• at 24 V / rated value	А	160
• at 110 V / rated value	А	2.5
with 2 current paths in series		
• at DC-1		
• at 24 V / rated value	А	160
• at 110 V / rated value	А	160
• at DC-3 / at DC-5		
at 24 V / rated value	А	160
• at 110 V / rated value	А	160
with 3 current paths in series		
• at DC-1		
at 24 V / rated value	А	160
• at 110 V / rated value	А	160
• at DC-3 / at DC-5		
at 24 V / rated value	А	160
• at 110 V / rated value	А	160
Service power		
• at AC-1 / at 400 V / rated value	kW	92
• at AC-2 / at 400 V / rated value	kW	84
• at AC-3		
• at 400 V / rated value	kW	55
• at 500 V / rated value	kW	81
• at 690 V / rated value	kW	11.3
Control circuit:		

Control circuit:	
Design of activation	conventional
Design of the surge suppressor	with varistor
Type of voltage / of the controlled supply voltage	AC/DC

Control supply voltage frequency		
• 1 / rated value	Hz	40
• 2 / rated value	Hz	60
Control supply voltage / 1	-	
• for DC		
initial rated value	V	220
final rated value	V	240
• at 50 Hz / for AC		
• initial rated value	V	220
final rated value	V	240
• at 60 Hz / for AC		
initial rated value	V	220
final rated value	V	240


Auxiliary	v circuit:
,	


Contact reliability / of the auxiliary contacts		1 faulty switching per 100 million (17 V, 1 mA)
Number of NC contacts / for auxiliary contacts		
instantaneous switching		2
lagging switching		0
Number of NO contacts / for auxiliary contacts		
instantaneous switching		2
leading switching		0
Operating current / of the auxiliary contacts		
• at AC-12 / maximum	А	10
• at AC-15		
• at 230 V	А	6
• at 400 V	А	3
• at DC-12		
• at 60 V	А	6
• at 110 V	А	3
• at 220 V	А	1
• at DC-13		
• at 24 V	А	10
• at 60 V	А	2
• at 110 V	А	1
• at 220 V	А	0.3

Short-circuit:

		_
Design of the fuse link		
 for short-circuit protection of the auxiliary switch / required 	fuse gL/gG: 10 A	
 for short-circuit protection of the main circuit 		

 with type of assignment 1 / 	required		fuse gL/gG: 355 A	
at type of coordination 2 / re			fuse gL/gG: 315 A	
	, 1	_		
nstallation/mounting/dimens	sions:			
Type of mounting			screw fixing	
series installation			Yes	
Vidth		mm	120	
leight		mm	172	
Depth		mm	180	
Distance, to be maintained, to ea	arthed part / sidewards	mm	10	
Connection type:				
esign of the electrical connect	ion			
 for main current circuit 			screw-type terminals	
• for auxiliary and control current	it circuit		screw-type terminals	
lentification number and letter	for switching elements		22 E	
ertificates/approvals:				
General Product Approval				Functional Safety Safety of Machinery
cqc CSA	<u>KETI</u>	<u>ROSTEST</u>		SUVA
Test Certificates Shipping	J Approval		other	
Manufacturer ABS	ĴÅ DNV DNV	GL	Manufacturer	<u>other</u>
urther information:				
nformation- and Downloadcento ttp://www.siemens.com/industrial				
dustry Mall (Online ordering s				
Ax-Online-Generator				
	ificates, Characteristics, FAQs .com/WW/view/en/3RT1054-1AP			
nage database (product images ttp://www.automation.siemens.co			ircuit diagrams,)	





last change:

Sep 30, 2011